

Fire Marshal Permit TENT

100 North 11th street Palatka, FL 32177
Phone: 386-329-0120 Fax: 386-329-0154

Project Name _____

911 Address _____

Plans Submitted by (print) _____ Cell _____

Purpose of Tent _____

Owner (print) _____ Signature _____ Date _____

Date Tent Will Be Erected _____ Expiration Date (determined by Fire Marshal) _____

\$50.00 PER TENT

1. All tents expire in 180 days per NFPA 101 3.3.217.8
2. A site plan FOR EACH SITE showing the location of the proposed tent(s) is required at the time of submission for this permit.
3. Per NFPA 101-11.11.3.1, a minimum distance of 10 feet is required between stakes lines.
4. Per NFPA 101-11.11.2.2, the fabric of the tent is required to be flame resistant. Fire resistance must be demonstrated by certificate or inspection by an approved party. **A copy of this certification is required at the time of submission.**
Per NFPA 101.11.11.3.1, any adjacent tents are required to spaced to provide an area for means of egress. Note: Where ten feet between stake lines does not meet required means of egress, the necessary distance shall govern.
6. Per NFPA 101-11.11.4.1, The ground enclosed in the tent and within ten feet of the tent must be clear of vegetation and combustible materials. Exception: Areas necessary for support equipment.
7. Per NFPA 101-11.11.4.2 and the City of Palatka Fire Prevention Office, smoking is not allowed in tents and **no smoking signs must be posted.**
8. Per NFPA 101-11.11.5 Fire extinguishers are required. Contact a licensed fire extinguisher dealer for mounting, tagging and placement.

Approved _____ Rejected _____ OT/HRS _____ PERMIT # _____

Fire Marshal

Date